Message Text

UNCLASSIFIED

PAGE 01 CARACA 11297 211320Z ACTION ARA-14

INFO OCT-01 ISO-00 EB-08 /023 W

-----071899 211323Z/53

O 211256Z NOV 77

FM AMEMBASSY CARACAS TO USDOC WASHDC IMMEDIATE INFO SECSTATE WASHDC 51

UNCLAS CARACAS 11297

EO 11652 NA TAGS: BEXP VE

SUBJ: US EXHIBITION STRUCTURE AIR CONDITIONING

FOR BREWER REF: USDOC 21727

1. A MEETING WAS HELD WITH CARRIER, COMATT, DUSEX, UNIVERSITY ENGINEER AND GSO IN ORDER TO ANSWER QUESTIONS IN REF. ANSWERS ARE AS FOLLOWS:

A. PROPOSAL DOES NOT INDICATE ANY TYPE OF REHEAT EQUIPMENT. CARRIER STATED REHEAT IS NOT NECESSARY TO CONTROL HUMIDITY BECAUSE HUMIDITY WILL NOT GO ABOVE 60 DEGREES.

B. PROPOSAL PROVIDES FOR FRESH AIR. SYSTEM HAS MANUAL DAMPER CONTROLLED FRESH AIR. SYSTEM DOES NOT TAKE ADVANTAGE OF CHANGING OUTDOOR CONDITIONS AND INTERNAL LOADS BECAUSE AMBIENT TEMPERATURE DOES NOT GO BELOW 60F.

C CARRIER HAS REVIEWED THEIR PROPOSAL AND WILL NOW PLACE ONE 4.5 TON UNIT ON LOWER ROOF FOR OFFICE COLLING, ONE 4.5 TON UNIT FOR LOUNGE COOLING, ONE 20 TON UNIT NEAR OUTSIDE STOREROOM DOOR FOR COOLING APPROXIMATELY ONE-THIRD OF EXHIBIT HALL AND ONE 30 TON UNIT ON GROUND AT SOUTH SIDE OF BUILDING TO COOL APPROXIMATELY TWO-THIRDS OF EXHIBIT HALL. ALL UNITS WILL HAVE SEPARATE CONTROLS.

2. THE REVISED PROPOSAL WILL NOT CHANGE THE ORIGINAL COST UNCLASSIFIED

UNCLASSIFIED

PAGE 02 CARACA 11297 211320Z

OF BS 281,264.00 OR \$65,800.00 PRICE DOES NOT INCLUDE MAIN CABLES FROM MAIN BREAKERS TO EQUIPMENT, CONCRETE FOOTINGS FOR EQUIPMENT, RETURN AIR SCREENS IN OFFICE DOORS AND PAINTING OF OUTSIDE DUCTS.

3. CARRIER'S ORIGINAL PROPOSAL STATED THEY WOULD HAVE REQUIRED EQUIPMENT AVAILABLE UNTIL NOV 1. NOW THEY WOULD

LIKE AN AFFIRMATIVE ANSWER BEFORE COB ON NOV 25 AS THEY FEEL THEY CANNOT HOLD EQUIPMENT BEYOND THAT DATE. ADVISE.

4. PROPOSAL, DUCT PLANS, BROCHURES, ETC. HAVE BEEN SENT TO UNIVERSITY ENGINEER, GSO AND SENT APO TO CMM. VAKY

UNCLASSIFIED

NNN

Message Attributes

Automatic Decaptioning: X

Capture Date: 01-Jan-1994 12:00:00 am Channel Indicators: n/a **Current Classification: UNCLASSIFIED**

Concepts: n/a Control Number: n/a Copy: SINGLE Sent Date: 21-Nov-1977 12:00:00 am

Decaption Date: 01-Jan-1960 12:00:00 am

Decaption Note: Disposition Action: n/a Disposition Approved on Date: Disposition Case Number: n/a Disposition Comment:

Disposition Date: 01-Jan-1960 12:00:00 am Disposition Event:

Disposition Event:
Disposition Reason:
Disposition Remarks:
Document Number: 1977CARACA11297
Document Source: CORE

Document Unique ID: 00 Drafter: n/a

Enclosure: n/a Executive Order: N/A Errors: N/A

Film Number: D770431-0116 Format: TEL From: CARACAS

Handling Restrictions: n/a

Image Path: ISecure: 1

Expiration:

Legacy Key: link1977/newtext/t19771136/aaaabelx.tel

Line Count: 68 Litigation Code IDs: Litigation Codes:

Litigation History: Locator: TEXT ON-LINE, ON MICROFILM Message ID: a8493e15-c288-dd11-92da-001cc4696bcc

Office: ACTION ARA

Original Classification: UNCLASSIFIED
Original Handling Restrictions: n/a
Original Previous Classification: n/a
Original Previous Handling Restrictions: n/a

Page Count: 2
Previous Channel Indicators: n/a Previous Classification: n/a
Previous Handling Restrictions: n/a

Reference: n/a Retention: 0

Review Action: RELEASED, APPROVED Review Content Flags: Review Date: 21-Jan-2005 12:00:00 am

Review Event: Review Exemptions: n/a **Review Media Identifier:** Review Release Date: n/a Review Release Event: n/a **Review Transfer Date:** Review Withdrawn Fields: n/a

SAS ID: 510876 Secure: OPEN Status: NATIVE

Subject: US EXHIBITION STRUCTURE AIR CONDITIONING FOR BREWER

TAGS: BEXP, VE To: COM Type: TE

vdkvgwkey: odbc://SAS/SAS.dbo.SAS_Docs/a8493e15-c288-dd11-92da-001cc4696bcc

Review Markings: Margaret P. Grafeld Declassified/Released US Department of State EO Systematic Review 22 May 2009

Markings: Margaret P. Grafeld Declassified/Released US Department of State EO Systematic Review 22 May 2009